

Certificate of Assessment

2 Component **SX Range of Enclosures**

	SX0	SX0.5	SX1	SX1.5	SX2
Models:	SX3	SX4	SX5	SX6	SX7
	SX8	SX45	SX64	SX66	

3 Manufacturer **Abtech Limited**

4 Address **Sanderson Street
Lower Don Valley
Sheffield S9 2UA
UK**

5 The components specified have been evaluated against the requirements of the standard specified in Section 7.

6 This evaluation is based on the following documents:

Report R108A

7 Specification: **IEC 60529:1989+A1:1999+A2:2013** **BS EN 60529:1992+A2:2013**
Petrobras Technical Specification: **ET-3010-00-1200-941-PPC-00**

8 **IP66W** **IP67**

9 Assessment This is to certify that, on the basis of the testing carried out, that the above model range of SX enclosures were considered to comply with the requirements listed in section 8, with respect to the Ingress Protection standards listed in section 7.

10 Date: 5th February 2014



D R Stubbings
Technical Director